





NOTES:

- 1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
- 2. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
- 3. ROOF PENETRATIONS EXCEEDING 120°F, REFER TO THE IB HOT PIPE FLASHING DETAIL.
- 4. CLEAN PENETRATION PRIOR TO FLASHING TO REMOVE ALL BITUMINOUS RESIDUE OR CONTAINMENTS.

Scale: NTS	Detail Name:	IB Pipe Flashing	Detail Number: PS - 01
Submitted By: Address: Telephone:		Project: Address:	