



NOTES:

1. MINIMUM BASE FLASHING HEIGHT 6" ABOVE THE ROOF.
2. SINGLE COURSE BASE FLASHING MAXIMUM HEIGHT IS 12" ABOVE THE ROOF, FOR BASE FLASHING HEIGHTS GREATER THAN 12" HEIGHT, TERMINATE MEMBRANE AT BASE OF WALL AND INCORPORATE A SEPARATE BASE FLASHING.

Scale: NTS	Detail Name: <i>Base Flashing at Siding Wall</i>	Detail Number: DS-07
Submitted By: Address: Telephone:	Project: Address:	