



## NOTES:

1. SINGLE COURSE BASE FLASHING MAXIMUM HEIGHT IS 12" ABOVE THE ROOF, FOR BASE FLASHING HEIGHTS GREATER THAN 12" HEIGHT, TERMINATE MEMBRANE AT BASE OF WALL AND INCORPORATE A SEPARATE BASE FLASHING.
2. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.

Scale:

NTS

Detail Name:

*Door Sill - Termination*

Detail Number:

*DS-11*

Submitted By:

Address:

Telephone:

Project:

Address: