



NOTES:

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
3. THIS DETAIL TO BE USED FOR ROOF PENETRATIONS EXCEEDING 120°F (HEATED STOVE PIPES, DRYER EXHAUSTS, FLUMES, ETC.)
4. CLEAN PENETRATION PRIOR TO FLASHING TO REMOVE ALL BITUMINOUS RESIDUE OR CONTAMINANTS.
5. EACH PIPE FLASHING IS DESIGNED TO ACCOMMODATE PIPE DIAMETERS RANGING FROM 1" TO 6". EACH BOOT HAS A CUTTING GUIDE, DIAMETER MEASUREMENTS, AND INCLUDES A METAL CLAMP.
6. IB TPO PIPE FLASHINGS ARE NOT TO BE USED OR FUNCTION AS A MOISTURE RELIEF VENT.

Scale: NTS	Detail Name: IB TPO Pipe Flashing for Hot Pipes	Detail Number: T-PS-05
----------------------	--	---

Submitted By: Address: Telephone:	Project: Address:
--	-----------------------------