



NOTES:

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. EXTEND REINFORCING FABRIC A MINIMUM OF 4" VERTICALLY AND FINGERS A MINIMUM OF 2" BEYOND PENETRATION

Scale: NTS	Detail Name: IB PMMA Flashing System at TPO Pipe Penetration	Detail Number: T-PS-12
----------------------	---	---

Submitted By: Address: Telephone:	Project: Address:
--	-----------------------------